



C Shift

Created by: (b) (7)(C), (b) (6) on 03/18 at 08:19 PM

Night Shift	Operators on Duty	Working for?	Why?
Inside:	(b) (7)		
Outside:	(b) (7)	allen	vac

Shift Log:

1. SO3 leak found above CIP escaping from continuously leaking spots , not being gathered by suction hoses . Seems to be travelling offsite will take a closer look at fence line . Mangement notified , left message, no answer. will try another method perhaps email or another supervisor .

Talked to (b) (7)(C), (b) (6) who advised to call

(b) (7)(C), (b) (6)

(b) (7)(C), (b) (6)



C Shift

Created by: (b) (7)(C), (b) (6) on 03/18 at 08:19 PM

Night Shift	Operators on Duty	Working for?	Why?
Inside:	(b) (7) (C), (b) (6)		
Outside:	(b) (6)	(b) (7) (C), (b) (6)	vac

Shift Log:

1. SO3 leak found above CIP escaping from continuously leaking spots , not being gathered by suction hoses . Same leak site as previously notified three weeks ago , seems to be travelling offsite will take a closer look at fence line . Mangement ((b) (7)(C), (b) (6)) notified , left message, no answer. will try another method perhaps another supervisor . Since, management previously advised not to email being it created a legal document . Got in touch with (b) (7)(C), (b) (6) who advised to contact (b) (7) to get some guys to come look at the leak as long as we had some doubt as to whether it was going off site . (b) (7)(C), (b) (6) called back and we updated her . Will call back if we can not stop leak .



C Shift

Created by: (b) (7)(C), (b) (6) on 03/19 at 04:12 AM

Night Shift

Operators on Duty

Working for?

Why?

Inside:

(b) (7)(C),
(b) (6)

Outside:

(b) (7)(C),
(b) (6)

DEA1

Shift Log:

1. (b) (7)(C), (b) (6) CALLED IN SICK FOR MONDAY .
2. CALLED KBR FOR "CIP" GAS LEAK. (REPAIRED BAD HOSE NOZZLES).
3. LOAD SO3 R/C.
4. POND PUMPING TO THE RIVER CONTINUES .